

# ALARM STATUS REPORT

**Chiller Plant**  
**CH-1 Before Bearing Chg**  
**POSITION : 1**  
**DIRECTION : Horizontal**  
**LOCATION : MTR-OB**  
**DATA TYPE : Magnitude**  
**UNITS : g's**  
**FILTER : High Frequency**  
**DATE/TIME : 4/2/2007 10:44 AM**

Method	Description	Value	Severity	Active	Exception
Mag Constant	Mag Above HI ALARM1	Above 1.5	Warning	Yes	Yes
Mag Constant	Mag Above HI ALARM2	Above 2.5	Critical	Yes	No
Mag Baseline	Mag Below Baseline - 50%	Below .383	Warning-Baseline	Yes	No
Mag Baseline	Mag Above Baseline + 50%	Above 1.15	Warning-Baseline	Yes	Yes

**Chiller Plant**  
**CH-1 Before Bearing Chg**  
**POSITION : 1**  
**DIRECTION : Horizontal**  
**LOCATION : MTR-OB**  
**DATA TYPE : Magnitude**  
**UNITS : g's**  
**FILTER : Smart HP**  
**DATE/TIME : 4/2/2007 10:45 AM**

Method	Description	Value	Severity	Active	Exception
Mag Constant	Mag Above HI ALARM1	Above 6.	Warning	Yes	Yes
Mag Constant	Mag Above HI ALARM2	Above 10.	Critical	Yes	No

